

#118508#

Тип теплосчётчика:

ТЭМ-104

Номер теплосчётчика:

1125637

Номер абонента:

Донского,2 ФК Балтика (поле)

Адрес установки:

Подача

Система

1

 $Q = M(h_p - h_o)$

Ведомость учёта параметров теплопотребления

статистические данные

с 21.02.2025 по 21.03.2025

Дата	Энергия	Масса, т	Температура, °C		Давление, МПа		Время наработки Тнар, ч
	Q, Гкал	M	t _n	t _o	P _n	P _o	
21.02	---	---	2,98	3,60	---	---	24,00
22.02	---	---	3,94	4,21	---	---	24,00
23.02	---	---	4,56	4,79	---	---	24,00
24.02	---	---	5,07	5,21	---	---	24,00
25.02	---	---	5,79	5,77	---	---	24,00
26.02	---	---	6,80	6,47	---	---	24,00
27.02	---	---	7,87	7,31	---	---	24,00
Итого:	0,00	0,0	5,29	5,34	---	---	168,00
28.02	---	---	8,45	7,93	---	---	24,00
01.03	---	---	7,68	7,64	---	---	24,00
02.03	---	---	7,48	7,33	---	---	24,00
03.03	---	---	8,13	7,75	---	---	24,00
04.03	---	---	8,94	8,39	---	---	24,00
05.03	---	---	9,67	9,00	---	---	24,00
06.03	---	---	10,40	9,61	---	---	24,00
Итого:	0,00	0,0	8,68	8,24	---	---	168,00
07.03	---	---	10,72	10,08	---	---	24,00
08.03	---	---	10,84	10,20	---	---	24,00
09.03	---	---	11,04	10,40	---	---	24,00
10.03	---	---	11,95	11,09	---	---	24,00
11.03	---	---	12,27	11,63	---	---	24,00
12.03	---	---	10,66	10,31	---	---	24,00
13.03	---	---	9,57	9,50	---	---	24,00
Итого:	0,00	0,0	11,01	10,46	---	---	168,00
14.03	---	---	6,36	6,95	---	---	24,00
15.03	---	---	4,12	5,27	---	---	24,00
16.03	---	---	3,04	4,44	---	---	24,00
17.03	---	---	2,57	3,81	---	---	24,00
18.03	---	---	2,27	3,07	---	---	24,00
19.03	---	---	3,67	4,42	---	---	24,00
20.03	---	---	3,96	4,78	---	---	24,00
Итого:	0,00	0,0	3,71	4,68	---	---	168,00
21.03	---	---	---	---	---	---	---
Итого:	0,00	0,0	---	---	---	---	0,00
Итого:	0,00	0,0	7,17	7,18	---	---	672,0
			dT=	-0,01			

Общее время работы, ч	696,0	=	Тнар, ч +	Тмах, ч +	Тмин, ч +	Тдт, ч +	Ттех.н, ч
	696,0	=	672,0	0,0	0,0	0,0	24,0
Количество тепла, Гкал	Q =	Q т/с +	Qmin +	Qmax +	Qош. +	Qт/в +	Qсан.ут.
		0,00					
Показания интеграторов	На 24:00 20.02.2025	На 24:00 20.03.2025	Результат за период	На 12:08 21.03.2025			
Количество теплоты, Гкал	422,84	422,84	0,00	422,84			
Масса теплоносителя M1, т	10552,4	10552,4	0,0	10552,4			
Время наработки, ч	11626,3	12298,3	672,0	12310,4			
Время неработы Тнер = Тмах + Тмин + Тдт + Ттех.н, ч			24,0				

Представитель абонента

Представитель теплосети

S10X v4.18

